



Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott
TODD W. BOYKIN, Vice President, Amarillo
PENNY C. CARPENTER, Secretary-Treasurer, Silverton
STEPHEN A. THORNHILL, Assistant Secretary, Denison
MICHAEL R. SANDEFUR, Texarkana
GEORGE WILSON SCALING, II, Henrietta
ZACKARY K. SMITH, Canyon
JOE L. WARD, Telephone

RANDALL W. WHITEMAN, General Manager
FABIAN A. HEANEY, Assistant General Manager
DANNA P. BALES, Executive Assistant
LANA HEFTON, Controller

February 11, 2022

NOTICE OF DRINKING WATER TOTAL TRIHALOMETHANES VIOLATION AND HALOACETIC ACIDS VIOLATION RRA – Preston Shores Water System, ID No. 0910037

The Texas Commission on Environmental Quality (TCEQ) has notified the Authority's Preston Shores Water System that the drinking water supplied by the system has exceeded the Maximum Contaminant Level (MCL) for TOTAL TRIHALOMETHANES (TTHM's) and HALOACETIC ACIDS (HAA5), as set in the Commissions Drinking Water Standards.

The MCL for TTHM's is 0.080 milligrams per liter (mg/L) and the MCL for HAA5's is 0.060 mg/L. Compliance with these levels is based on a running annual average of quarterly sample results. Preston Shores Water Systems running annual average for TTHM's in the fourth quarter of 2021 from DBP2-01 was 0.142 mg/L and DBP2-02 was 0.150 mg/L. The running annual average for HAA5's in the fourth quarter of 2021 for DBP2-02 was 0.062 mg/L.

This is not an emergency. However, some people who drink water containing trihalomethanes or haloacetic acids in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

The Authority is working with engineers looking for an alternative solution to resolve these MCL violations. The Authority will continue to send letters out until the running annual average is below the required MCL.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For further information, please contact Mr. Ron Mullins, Utility Regulatory Officer, at the Red River Authority of Texas at (940) 723-8697. You may also contact your District Manager, Mr. Jason Whaley, at (903)786-9303.

Sincerely,

RED RIVER AUTHORITY OF TEXAS

A handwritten signature in black ink that reads "Ronald A. Mullins".

Ron Mullins
Utility Regulatory Officer

RAM:slf

P.O. Box 240 · Wichita Falls, Texas 76307-0240
Texas 76310-7500

Telephone: (940) 723-8697

E-Mail: info@rra.texas.gov
(940) 723-8531

3000 Hammon Road · Wichita Falls,

Fax: